

Government of Tripura
Directorate of Fire & Emergency Services
Tripura, Agartala.

Phone: 0381-2326451. Fax: 0381-2324826. Email: dfireservice@tripura.gov.in. Website: www.fireservice.tripura.gov.in

No.3-8/TFES/2021/ 4722-24

Dated, Agartala, the 04th June, 2021.


✓ To
The Principal,
Bethany School,
East Champamura,
Old Agartala, Khayerpur, West Tripura.
Email - jry.d63@gmail.com
Mobile No. 7640984902, 9402722957.

Subject: - Issuance of Fire NOC.

With reference to your compliance report under letter No. No. BS-L 24,19/21 dated 02.06.2021, it is hereby certified that the building /premises as per description below has been inspected by the officer concerned of this department on 02.06.2021. In respect of implementation of Fire Safety measures, it was found that said building have complied with the Fire Prevention and Fire Safety requirements in accordance with provisions of the Part-IV of the latest National Building Code, 2016. The premises/building is issued NOC with effect from 04.06.2021 for a period of 01 (one) year subject to compliance of the conditions for the validity of Fire NOC.

Name & address of the proposed building / premises: - Bethany School, East Champamura,
Old Agartala, Khayerpur, West Tripura.

Issued on 04.06.2021 at Agartala.



Joint Director,
Tripura Fire & Emergency Services.


Conditions for the Validity of Fire NOC.

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all times. Any lapse in this regard shall make the owner /management liable for action.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to the brim.
5. The entrance and exit and the water reservoir should always be free from any obstructions.
6. The staff shall be trained for operating fire fighting system and mock evacuation drills be Conducted at regular intervals and record be maintained.
7. Construction of remaining 9000 ltrs. of Terrace level tank should be done early otherwise renewal of NOC would not be issued.

Copy to :-

1. The Divisional Fire Officer, West Division, Agartala for information.
2. OC, Agartala Fire Station for favour of information.


Principal
BETHANY SCHOOL
East Champamura,
Old Agartala, Khayerpur,
Tripura West, Pin-799008


Manager
BETHANY SCHOOL
East Champamura,
Old Agartala, Khayerpur,
Tripura West Pin-799008